

TOWN OF SPRINGFIELD
WATER SYSTEM DIVISION
MONTHLY REPORT
OCTOBER 2022

Along with the following projects the Water Division personnel performed daily, routine monitoring of pump stations, water tanks, telemetry pits and the Reservoir.

1. Replaced fire hydrant near 111 Carley Rd.
2. Performed seven (7) waters off and/or on.
3. Seven (7) final reads or closings were done. (Sale of Property).
4. Replaced two (2) meters.
5. Repaired or replaced two (2) remote readers.
6. Performed one (1) re-read. Customers concerned with their water usage or irregular readings on water usage.
7. Repaired fire hydrant on Wall St.
8. Turned water off and removed meters at Town cemeteries and parks.
9. Located water lines and curb stops for various contractors.
10. Inspected and flushed all fire hydrants owned by the Water Department.
11. Repaired water main on Giddings St.
12. Mowed and trimmed at the water pump stations and pressure reducing vaults.
13. Trimmed and removed brush at the west side tank (High School Tank).
14. Ten (10) routine Coliform samples taken.
15. Routine Synthetic Organic Chemical (SOC) samples were taken at Chapman 1 and Chapman 2 pump stations.
16. Trimmed brush around various hydrants in town.
17. Assisted Parks and Rec. department with winterizing the pool and baseball field.
18. Assisted Wastewater Collection division with repairing three (3) manhole covers.
19. Water personnel worked with owner of trailer park on Patnode Way to find water leak.
20. Collected on delinquent accounts.
21. Took delivery of new S-8 service truck.
22. Adjusted two (2) gate valve boxes that were paved over on Union St.
23. Field mowed the well field.