

TOWN OF SPRINGFIELD  
WATER SYSTEM DIVISION  
MONTHLY REPORT  
APRIL, 2022

Along with the following projects the Water Division personnel performed daily, routine monitoring of pump stations, water tanks, telemetry pits and the Reservoir.

1. Performed leak check @ 377 River St.
2. Performed five (5) water off and / or on.
3. Changed/updated six (6) water meters.
4. Investigated rusty water complaint on Wall St. area.
5. Ten (10) routine Coliform samples taken.
6. Removed downed trees in the Wellfield.
7. Installed Radio Reads as needed to improve meter reading efficiency and safety.
8. Excavated and removed 6" valve into 33 Park St. due to leak.
9. Performed eight (8) closings/final reads (sale of property).
10. Excavated and replaced erie box and rod at 5 Curtis St.
11. Assisted Wastewater Collection Division.
12. Water Dept. personnel worked on locating curb stops, valve boxes, etc. for the upcoming paving streets.
13. Contractor Weston & Sampson installed new motor and pump at Chapman 1 pump station with our assistance.

14. Two (2) Re-reads were performed.
15. Removed hydrant markers from hydrants.
16. Turned off winter by-passes. (Running water to waste to prevent freezing)
17. Started on this years lead removal based on the Town's Lead Removal Plan.
18. Replaced water service @ 4 Hill Place St. after finding lead a gooseneck.
19. Performed three (3) exploratory excavations searching for lead goosenecks on Hill Place St.
20. Worked on cleaning up our inactive accounts list for meter reading purposes.