

MONTHLY ACTIVITIES
WWTP
August 2023

1. Monthly monitoring of the Pretreatment Facility and Western Seep.
2. Submitted WR-43 reports for the Treatment Plant
3. Wastewater Collections continues to respond to trouble calls in different locations around town, inspecting and maintaining the collections system.
4. Maintenance and service to equipment at WWTP and Pump Stations.
5. Plant operators have been busy with routine seasonal grounds maintenance.
6. Plant operators have been working on interior building maintenance.
7. Plant operators have been rotated into different positions at the WWTP in an effort to better understand different roles and cross train all employees. This will enable us to react more efficiently to daily needs.
8. Assisted Cavendish with Vactor truck and employees for more storm related damage.
9. Mobil Solid Solutions (Denali) started and completed cleaning of our Secondary Digester Cleaning
10. Removed 480 line and conduit used for powering mobile belt filter press.
11. Continued repairs at Giddings bridge sewer line in North Springfield.
12. Ptf air cleaning balls installed in tower
13. Did complete maintenance on belt filter press including steam cleaning belts
14. Plant operator completing bi-annual maintenance on clarifiers.
15. Mechanics were able to weld and bolt a metal plate that had ripped away from royer.
16. Plant operator to replace brushes and adjust tension on springs to account for excessive wear and longevities.

The personnel at the treatment plant performed daily operations to ensure that the final effluent remains exceptional and the solids handling continues to perform well. We had no reportable outfall violation for the month of August 2023.