

TOWN OF SPRINGFIELD  
WATER SYSTEM DIVISION  
MONTHLY REPORT  
August,2023

Along with the following projects the Water Division personnel performed daily, routine monitoring of pump stations, water tanks, telemetry pits and the Reservoir.

1. Ten (10) routine Coliform samples taken.
2. Performed five (5) water off and/or on.
3. Eleven (11) Closings were done. (Sale of Property).
4. Replaced two (2) meters.
5. Collected on delinquent water and sewer accounts.
6. Rebuilt the yard hydrant by the Co-op for the garden club.
7. All employees attended a trenching and confined space safety class.
8. Performed routine water sampling for Nitrates, VOC's, and disinfection by products.
9. Repair storm damage to electrical components at Gilchrist pump station and Hartness Park water tank.
10. Assist highway with paving previous water dig locations.
11. Continue with the Clinton st water line project. (mark lines, finish laying new pipe, chlorinate and flush, pressure test, start connecting houses)
12. Locate and mark lines and curbstops for several contractors around town
13. Rebuilt chemical feed pumps to both Chapman 1 and Chapman 2
14. Had annual visit from the state fluoride regulator. Took him around to all pump stations.
15. Repaired water leak 44 county rd.
16. Fixed a leaking bypass.
17. Mow and trimmed all water properties.
18. Fit in a few much needed vacation days for operators.